

RIVERSIDE PARK ATHLETIC FIELD IMPROVEMENTS

SEPTEMBER 21, 2021

ADDENDUM NO. 1, Part 1

CONTRACT NO. RP21809

TO BIDDERS: THIS ADDENDUM IS HEREBY MADE A PART OF THE CONTRACT DOCUMENTS ON WHICH THE CONTRACT WILL BE BASED, AND IS ISSUED TO MODIFY, EXPLAIN AND/OR CORRECT THE ORIGINAL DRAWINGS AND SPECIFICATIONS. PLEASE ATTACH THIS ADDENDUM TO YOUR CONTRACT DOCUMENTS AND ACKNOWLEDGE IT ON THE BID OR PROPOSAL PAGE WHERE INDICATED.

APPROVED:



Adam Boarman, RLA
CHIEF OF CAPITAL DEVELOPMENT
DEPARTMENT OF RECREATION AND
PARKS



Reginald Moore
DIRECTOR OF RECREATION AND PARKS

2019 Revision

RESPONSES TO REQUEST FOR INFORMATION / CLARIFICATION:

QUESTION 1: Does the 10" water line get abandoned under this contract?

ANSWER: Yes. See sheet C-401 and DA #1730

QUESTION 2: Does the 10" water line get replaced under this contract?

ANSWER: No.

QUESTION 3: We do not have the Developer Agreement plans, will they be provided?

ANSWER: Developer Agreement #1730 is provided in the project Specifications, page 229A- 229E. A digital copy is attached to this Addendum for bidders use as well. See Addendum No. 1, Part 2.

RIVERSIDE PARK ATHLETIC FIELD IMPROVEMENTS

SEPTEMBER 21, 2021

ADDENDUM NO. 1, Part 1

CONTRACT NO. RP21809

QUESTION 4: Is irrigation part of this job?

ANSWER: Yes. See Specification 32 84 00, Part 1.2, A. for description of included work.

QUESTION 5: Sheet C-401 What does the W-2 notation indicate on the plan view?

ANSWER: Disregard note W-2 on plan.

QUESTION 6: Does the water and storm drain work within the CSX ROW require special insurance?

ANSWER: BCRP is not aware.

QUESTION 7: Is any work on the Developers Agreement Plans (which we don't have) on Johnson Street part of this project?

ANSWER: Yes, utility work and concrete paving.

QUESTION 8: Is the actual score board furnish and installation a part of this contract, or just the electric leading to it?

ANSWER: Yes, furnish and install scoreboard is part of the contract. See sheet C-201, note C-31.